

ADDENDUM #1

2015 Brushy Creek MUD

Shirley McDonald Shade Structure and Equipment Project Questions and Answers

1. Is/Was the site visit mandatory?

The site visit was not mandatory.

2. Regarding the fabric for the canopy, is the fabric intended to be water tight or is the fabric intended to be a mesh material and only provide sun shade?

The canopy is only required to provide shade and is not required to be water proof.

3. Regarding payment, the bid states only “payment upon completion of installation”. Are there provisions for an initial deposit upon award of the contract for raw materials, manufacturing, fabrication and mobilization?

The District will work with the selected vendor on payment and/or down payment options.

4. Do you want one large shade to cover both play areas or do you want two separate shades?

The District would prefer two separate shades, due to the elevation differences in the separate play areas. Both shade structures may share a post if the vendor provides such a design.

5. Will the District be removing any trees prior to the installation of the shade structures?

No trees will be removed; however, the District will prune any necessary trees.

6. How are we to access the work area?

Prior to the project start, an access gate will be installed by the District near the 5-12 existing playscape area.

7. Are we to remove the existing edging, equipment, and pea gravel?

The vendor is to remove all existing edging, pea gravel and equipment and haul such equipment to the District’s Maintenance Yard, approximately .5 miles from the site.

8. What is the height to be of the entry point of the shade near the existing swings?

Vendor must ensure that the height of the entry height is compliant and may need to be more than 12 feet high, or vendor must provide a secondary option to provide shade over the structure only and not the swing area.

9. Are any permits required?

Permits are not required, however, the vendor is to ticket the # of locates and provide the District with those ticket #'s. The District will do TAS review. ADA Requirements must be met.