

Town of Occoquan

Questions from Pre-Bid Meeting for River Trail Water Access

Installation of a Non-Motorized Watercraft Launch

June 28, 2017

Q: How long is the concrete “Deck to Parking Transition” shown on sheet 1 of 2 of the “Exhibit Showing Proposed Floating Dock, Kayak Launch & Gangway?”

A: The concrete “deck to parking transition” should extend six (6) inches past the decking on both sides, making the total length eleven (11) feet.

Q: Does the Town have any geotechnical reports which could be used for the design of the pilings?

A: No.

Q: Does the Town have any existing designs for the pilings?

A: No.