

Circle Hill Road
Bid Number 1617-Eng 6
ADDENDUM 1

Whenever there is a conflict between this addendum and the initial proposal or plans, the addendum shall take precedence.

The typical section shows a 1-1/2" layer of asphalt and a 1" layer of asphalt. The 1" layer is eliminated. There will only be 1 layer of 1-1/2" asphalt.

Note 37 on sheet C-1 is in error. Clearing and grubbing will be to the limits indicated on sheet C-4, which is 32 feet wide and 20' high.

The road width (asphalt) has been reduced to 20 feet wide paved. The striping detail will also be reduced by two feet. The width between side lines will be 19 feet and the lane width will be 9.5 feet. RPM's will be placed on the centerline striping.

The Alternate for chip seal has been eliminated.

Bidder must acknowledge receipt of all addenda as indicated on the bid form. Failure to acknowledge receipt of addenda may invalidate the bid. Both the bid form and the Pricing Sheets must be submitted with the bid.

Attachments: Revised form of Bid Proposal
Revised Drawing C-2
Revised Drawing C-4
Drawing Rework Cox at Circle Hill C-7
Drawing Plan View C-8
Drawing Plan View C-9
Revised Form of Proposal