



February 15, 2019

ADDENDUM #1

IFB 19-08 CHURCH STREET NW SIDEWALK

*******ATTENTION BIDDERS*******

(To be completed and returned with bid response)

1. Q: The Plans Require the replacement of the Speed Hump located within the project limits, however there is no pay item. How is the contractor being compensated for this work?
A: Pay items for speed hump reconstruction are included within pavement quantities and milling (flexible pavement planning) items.
2. Q: Are there any striping requirements on the Speed Hump? How is the contractor being compensated for that striping (no chevron's are included in price schedule)
A: Pavement marking for speed hump is shown on Sheet 4, and labeled accordingly. Pay items for the striping are provided with item #53.
3. Q: Please Provide the Missing Specifications / Approved Materials for the Permeable Sidewalks.
A: Per the plans, as noted on Sheet 2, the details and minimum requirements for this are provided. The eventual Contractor (as also noted on Sheet 2) shall present to the Town the permeable sidewalk material meeting these requirements (similar to shop drawing approvals) for approval prior to purchase and installation.
4. Q: What is Item No 9 Being Utilized For?
A: Refer to Sheet 2, Pavement General Notes, Note #2.
5. Q: For Item 29, are the Contractors being required to pay for the Utility Bracing?
A: Yes & coordination with utility owners. (All of their costs)
6. Q: For Item 40, it states that the "Contractor shall be responsible for costs, by a third party of the Town's choice, for watering new trees within Town of Vienna "Right of Way" for 360 days on a regular watering schedule." What is the costs for the watering, and what is the "regular schedule" in which the town will be adhering to?
A: The intent of this item is to help ensure the survivability of the trees. The wording has been revised to a third party of the Town's approval, not choice. Contractor shall provide a cost for this service. There is no prescribed schedule.
7. Q: Is the Costs to resurface at least 5' of adjoining driveways going to be paid under the associated line item descriptions?
A: Yes, and this cost is considered incidental to all the items, and this 5' is beyond the limits of that shown on the plans to ensure a smooth and satisfactory tie to existing conditions and shall not/will not be paid for separately.
8. Q: Sodding is provided as a pay item, specifications note sodding is incidental. Please clarify intent.
A: The sodding pay item is for all the disturbed area within the project. The specification note referencing that sodding is incidental is for when landscaping or disturbed areas affect property adjacent to the project that needs to be fixed/restored due to unintentional impacts.



TOWN OF
VIENNA
since 1890

9. Q: Concrete Flume is provided as a pay item, specifications note that no payment will be made for the concrete flume. Please clarify intent.

*A: Section B, II Scope, 2f, paragraph 2 shall read
"All costs related to concrete flume (materials, labor, equipment, concrete, rebar, mortar, sealant, construction joint materials, shop drawings, positive water test, grading, re-sodding, rip-rap if determined necessary etc.) to the satisfaction of the Town Engineer shall be included in Item #47 on the Bid Form."*

10. Q: How are the contractors to be compensated for the relocation of trees at #342 and #344 Church Street?

A: See line item #36.

11. Q: Is the contractor required to replace any of the copper, meter setters, pits, frame and grates as part of the requirement for item No 27?

A: Yes

ALL OTHER TERMS, CONDITIONS, AND SPECIFICATIONS SHALL REMAIN THE SAME.

A copy of this signed addendum must accompany your response as an acknowledgment of its receipt:

NAME AND ADDRESS OF VENDOR:

PHONE #: _____ EMAIL: _____

NAME OF AUTHORIZED REPRESENTATIVE: _____
Please Print

SIGNATURE: _____ DATE: _____