

JACKSON ROAD PROJECT
BOARD OF COUNTY COMMISSIONERS
JACKSON COUNTY, FLORIDA
FDOT FPID # 440635-1-54-01
BID # 1819 Eng 1
ADDENDUM 2

Whenever there is a conflict between this addendum and the initial proposal or plans, the addendum shall take precedence.

Following are questions that were received along with the answers:

Question: The bid schedule lists item #39 as "Relocate Hydrants", and item #40 as "Extend / Relocate Hydrant Valves w/ Box & Cover". Our review of the plans only shows extending the 6" pipe where hydrants are currently located. Is there a revised set of plans showing more hydrant relocations? If not how would you like us to price these two items?

Answer: As discussed in the pre-bid meeting, bid the items per the numbers listed in the bid items. It is possible that some of the hydrants were missed on the drawings. The intent is to relocate the existing hydrants, valves and meters. No additional hydrants or meters will be added.

Question: Item #42 on the bid schedule is listed as Relocate & Extend Sampling Points. The plans don't show any details for these sampling stations or their locations. How would you like us to price them?

Answer: The sampling points are buried in or beside the road and need to be moved out of the road so that they are accessible and can be samples. Bid the number of sampling points listed in the bid items. The As-Builts for the water line are attached.

Bidder must acknowledge receipt of all addenda as indicated on the bid form. Failure to acknowledge receipt of addenda may invalidate the bid. Both the bid form and the Pricing Sheets must be submitted with the bid.

Attachments: As Builts for Water Line.