



Public Utilities
230 Hospital Road
P.O. Box 761
Smithfield, NC 27577
919-934-2798 919-934-1688 (fax)
Email: tammy.mclamb@smithfield-nc.com

FORMAL REQUEST FOR QUOTE
(THIS IS NOT AN ORDER)

SEALED QUOTES will be received by the Town of Smithfield until **3:00 p.m., Thursday, August 8, 2019**, at which time they will be publicly opened and read for the purchase of materials for the Booker Dairy Road North Feeder New Overhead Addition.

Please quote your best price, delivery (Smithfield, NC.) *Items are subject to separate award.* Alternate quotes may be considered on products that are equal to or better than the specified product, **except when noted for OKONITE only.**

To receive consideration, **sealed quotes MUST BE mailed or hand delivered** to Smithfield Public Utilities Dept., P.O. Box 761, 230 Hospital Rd., Smithfield, NC, by **3:00 p.m., Thursday, August 8, 2019.** **Quotes received after this date will not be considered.** The Town of Smithfield reserves the right to reject any or all quotes.

For technical questions, please contact: Rodney Johnson 919-934-2230.

Item #	TOS Bin #	Item/Description	Qty.	Unit Price	Total	Lead Time
1	25E2.2	PLE225CC05TCPX New PT# for 25kv Load break UG Elbow with Posi-Break, ONLY, NO Equivalent	4			
2	G7.1	guy guards Cat# 70-7Y or PG-6000SC Guy Guard Yellow or equal	140			
3	AN6.08	J6528WCA 8" Helix, 1" x 66" screw anchor Joslyn# orequal	2			
4	AN6.10	J6550WCA 10" Helix, 1-1/4" x 8' screw anchor Joslyn# or equal	105			
5	AN6.16	J6528WCA 16" Helix, 1-1/4" x 8' screw anchor Joslyn# or equal	7			
6	T40.3	25kva CSP 240/120 secondary voltage, pole mounted overhead transformer, dual hangers, Lightning Arrester, Primary Dual voltage 22860/13200x12470/7200	1			

7	L1.1	Extension Link, Insulated, Clevis-thimble Eye 5/8" hole (21,000lbs) Chance #GS21012 CP or equal	68			
8	L8.2a	Arrestor, lightning (Riser Pole) (18kv MOV type) ARP type polymer Aluma-form or equal	6			
9	L8.2	Arrestor, lightning Heavy Duty (18kv MOV type) AHD type polymer Aluma-form or equal	67			
10		Switch Disconnect 600amp, pole mounted 27kv D73P29SO Cooper or equal	6			
11	25T1.1	TFT-253E-750kcmil kit w/2 hole connector Or equal	4			
12	25T2.1	TFT251E-1/0 Raychem 25kv terminator with 1/0 pin connect/stem or equal	4			
13	C9.1	Bracket, Insulator Spool, Joslyn # J093 Or equal	221			
14		Bracket, Three Phase Fiberglass, termination/arrestor mounting, Hubbell # 3SBM3618AMTB or equal	2			
15		Crossarm Mounting Bracket, Cutout/Arrestor, Hubbell # PSC2060674 or equal	67			
16		H-tap connector PENN-UNION # KO-R08 Or equal	90			
17		H-tap connector PENN-UNION # KN-0 or equal	130			
18		H-tap connector PENN-UNION # KO-R10 or equal	51			
19		Vise-Type Connector for equipment ground for three phase transformer Hubbell # GC-207 or equal	2			
20		Cut point hot dipped galvanized staples Joslyn # J1672G	10,000			
21	U10.6	10' x 6" U-guard PV-Mold Carlon # 59017N Or equal	3			
22	U10.4	10' x 4" U-guard PV-Mold Carlon # 59015N or equal	3			
23	WC3.06	#2 copper Solid soft drawn small reels 250'	500'			
24	WC3.05	#4 copper Solid soft drawn small reels 250'	5000'			
25	G1.1	ERICO # HDC58R ground rod clamp or T&B JAB58H ground rod clamp 5/8 1/0S or equal	95			

26	H8.1	Hubbell # BH4 hot line clamp or equal	34			
27	D5.3	Clamp Deadend, Neutral Fargo # GDW2040A or equal	76			
28	D5.4	Clamp Deadend, Primary Anderson # ADEZ88N or equal	363			
29	S1.1	Clamp Stirrup, Anderson # AHLS397021E or equal	31			
30	25C2.1	LBU-II, Y2NEBNFA22 ABB# 25kv 200amp cutout, load break, or equal	33			
31		Adapter, Insulator, DA to Insulator Chance # DP1A1 or equal	5			
32	C9.1	Insulator, spool ANSI 53-2 Joslyn # J101 or equal	225			
33		Insulator, Polymer Deadend 25KV Victor # 8225 or equal	382			
34		Insulator, Pin Type, 25kv Victor # 27R or equal	978			
35		Insulator, Guy Strain Aluma-Form # FGS21-54CR or equal	119			
36		Double Side Tie PLP# DBST-1108 or equal	108			
37		Double Support Tie PLP# DST-0158 or equal	15			
38		Spool Tie PLP# SPL-1355-P or equal	112			
39		Top Tie PLP# UTC-1110 or equal	708			
40	DAB2.10	Bolts, Double Arming, 5/8" x 10" Joslyn # J8860 or equal	50			
41	DAB2.22	Bolts, Double Arming, 5/8" x 22" Joslyn # J8872 or equal	225			
42		Bolt, Machine 1/2" x 6" with nut Joslyn # J8706 or equal	4			
43		Bolt, Machine 1/2" x 12" with nut Joslyn # J8712 or equal	8			
44		Bolt, Machine 5/8" x 6" with nut Joslyn # J8806 or equal	100			
45	B2.08	Bolt, Machine 5/8" x 8" with nut Joslyn # J8808 or equal	300			
46	B2.10	Bolt, Machine 5/8" x 10" with nut Joslyn # J8810 or equal	300			

47	B2.12	Bolt, Machine 5/8" x 12" with nut Joslyn # J8812 or equal	2100			
48	EB3.12	Oval Eye Bolt 5/8" x 12 with nut Joslyn # J9412 or equal	15			
49		Oval Eye Bolt 3/4" x 12 with nut Joslyn # J9512 or equal	25			
50		Lock Nut 5/8" Joslyn # J8583 or equal	3540			
51	E5.58	Eye Nuts 5/8" Joslyn # J1092 or equal	388			
52	H6.1	Screw, Lag 1/2" x 4" Joslyn # J8754P or equal	188			
53	W1.1	Washer, Square 2 1/4" x 2 1/4" x 1/4" with 11/16" hole or equal	5340			
54		Washer, Lock Joslyn # J139 or equal	500			
55	P14.1	Pin, Pole Top 20" Joslyn # J720Z or equal	127			
56		Pin, Crossarm Pin Type 1-3/8" Thread Joslyn # J3324Z or equal	807			
57		Pin, Crossarm Pin Type 1-3/8" Thread Joslyn # J647Z or equal	50			
58		Brace, Cross, Wood 60 x 30 Hubbell # PSCRA6030 or equal	2			
59		Crossarm, Fiberglass, 3-5/8" x 4-5/8" x 10' w/ Center mount- heavy duty (dead end) PUPI # DA2500120E3B7X2 or equal	87			
60		Crossarm, Fiberglass, 3-5/8" x 4-5/8" x 10' w/ Center mount-heavy duty (tangent) PUPI # TB250012005X2 or equal	271			
61		Crossarm, Fiberglass, 10' Alley arm w/mount & brace-heavy duty PUPI # D100005 or equal	4			
62		Crossarm, 3-3/4" x 4-3/4" x 10' Hughes Bros or equal	9			
63		Crossarm Brace wood 60" Span Hughes Bros or equal	20			
64	GD6.716	Guy Deadend Fargo# GDE5203 or equal	320			
65	G4.1	Guy Attachment Chance # GEP5A or equal	181			
66		Guy Wire 7/16" High Strength Steel galvanize	6820'			

67		Pole Plate Maclean # SWGB-20-54 or equal	5			
68		Strut End Fitting Maclean # SWG-20-5 or equal	5			
69		Strut Pipe Assembly 2” x 10’ Galvanize pipe Sidewalk guy	50’			
70		Shackle, Anchor Maclean # J2742 or equal	480			
71	G3.1	Rod, Ground 5/8” x 8’ copper bonded Joslyn # J8338-13	97			
72	WO3.10	1/0 AWG ACSR “RAVEN” (mFT)	7.5724 (mft)			
73	WO3.03	4/0 AWG ACSR “Penguin”	1.0065 (mft)			
74	WO3.15	336 kmcil ACSR “Merlin”	99.8646 (mft)			
75	WU3.06	1/0 25kv solid Aluminum 1/C UR-OJ, EPRSC 260-30 CAT#161-23-4069, each reel to be 2500’ per reel. Okinite only	1reel (2500’)			
76	P15.07	35’ CL4 REA spec. wooden pole CCA treated	1			
77	P15.09	40’ CL4 REA spec. wooden pole CCA treated	4			
78	P15.11	45’ CL3 REA spec. wooden pole CCA treated	23			
79	P15.13	50’ CL2 REA spec. wooden pole CCA treated	59			
80	P15.16	55’ CL2 REA spec. wooden pole CCA treated	52			
81	P15.17	60’ CL2 REA spec. wooden pole CCA treated	10			
82	P15.19	65’ CL2 REA spec. wooden pole CCA treated	2			
83	T60.05	150kva three phase pad mount transformer 208/120 secondary voltage, loop feed, bayonet fused, screw in bushing well with 25kv inserts, Primary Dual voltage 22860/13200x12470/7200	1			
84	J2.3	Junction cabinets, Three Phase, with three 600a/200a 4 point junctions installed, (600amp on each side and 200amp in the middle of each 4 point junction), Nordic # ND683054MGPB71425CB3B or equal	4			
85		Outdoor power vacuum circuit breaker 25kv 150kv bil, 20,000-amp interrupter <i>see attached sheet for specs.</i>	2			

COMPANY NAME:
Date:
Bid Submitted By:
Street Address:
City/State/Zip:
Phone #:
Fax #:
Email:
Quote Valid for _____ days
Delivery Guaranteed _____ calendar days after receipt of order