



Indian Springs Phase 2A Sewer Extension

To: Bidders

From: Eric Worrell, EOR
Company: Alday-Howell Engineering, Inc.
Email: eric@aldayhowell.com

Date: 12/8/2020

Number of Pages
(Including Cover): 2

Regarding: Bidder Questions 1

The following questions were posed by potential bidders. Answers are provided by the Engineer of Record:

Question #1: Question about unsuitable material when installing gravity sewer:

Pay Item 0120-2-21 has been added for Clean Common Fill, A-2, A-3, A-2-4, Truck Measure. Pay Item 0120-2-22 has been added for Select Common Fill, A-2, Truck Measure.

Question #2: Is there any manhole coating on the above referenced project?

All manholes in this project must be coated with Spectrashield according to Specification 02100 and manufacturer's recommendations.

Question #3: The specs state contractor is required to submit payroll records for compliance with Federal Wage Requirements but I don't see the wage rates / classification page showing required wages. Does this project require certified payroll and if so will wage rated be provided?

It is not required for this project. Bid Documents C-340 and C-720 have been removed and are not required to be submitted.

If you have any questions, please feel free to contact me.

Sincerely,

Eric Worrell, P.E.
Engineer of Record