

ROBERTSON LOIA ROOF  
ARCHITECTS & ENGINEERS

Addendum Number One

RFP # 0440-0401-145  
Cartersville, GA  
RLR Project No. 19-357  
April 20, 2021

TO: Prospective Proposers

This addendum forms a part of the Proposal Documents and modifies the Documents by additions, deletions, clarifications or corrections. Where a portion of the Documents is modified by this Addendum, the unaltered portions of the Documents shall remain in effect. Acknowledge receipt of this Addendum on the proposal. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of **Two (2 items)**

**CLARIFICATIONS (Questions):**

**ITEM NO 1:**

**No offsite fill required for excavated foundation back fill. Back fill with on site fill.**

**ITEM NO 2:**

**Compaction of excavation area fill will be tested by 3<sup>rd</sup> party owner engaged testing company.**

**END OF ADDENDUM No. 1**